

Model Number

NCB2-12GM35-N0-5M

Features

Comfort series •

Accessories

EXG-12 Quick mounting bracket with dead stop BF 12 Mounting flange, 12 mm

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 1111

fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com ⁵ PEPPERL+FUCHS

Technical Data		
General specifications		
Switching function		Normally closed (NC)
Output type		NAMUR
Rated operating distance	s _n	2 mm
Installation		flush
Assured operating distance	sa	0 1.62 mm
Actual operating distance	s _r	1.8 2.2 mm typ.
Reduction factor r _{Al}		0.23
Reduction factor r _{Cu}		0.21
Reduction factor r ₃₀₄		0.7
Output type		2-wire
Nominal ratings		
Nominal voltage	U _o	8.2 V (R_i approx. 1 k Ω)
Switching frequency	f	0 1000 Hz
Hysteresis	н	1 10 typ. 3 %
Reverse polarity protection		reverse polarity protected
Short-circuit protection		yes yes - Deverse polerity protection diade not required
Suitable for 2.1 technology		yes, neverse polarity protection didde not required
Moscuring plate pot detected		>3 mA
Measuring plate not detected		<1 mA
Switching state indicator		all direction LED, vellow
Eurotional safety related parameter	**	an unection LED, yenow
	15	0000 -
Mission Time (T_)		2099 a
Diagnostic Coverage (DC)		20 a
Ambient conditions		0 /8
Ambient temperature		-25 100 °C (-13 212 °F)
Machanical anasifications		-40 100 C (-40 212 P)
mechanical specifications		
Connection type		cable PVC, 5 m
Core cross-section		U.34 mm ⁻
Rousing material		DDT
Degree of protection		
Cable		11 07
Bending radius		> 12 x cable diameter
General information		
Soopo of dolivory		2 colf looking puts in scope of delivery
Lico in the bazardous area		2 sel locking huis in scope of delivery
Category		1G: 2G: 3G: 1D: 3D
Compliance with standards and		14, 24, 64, 10, 60
directives		
Standard conformity		EN 00047 E 0.0000
NAMUR		EN 60947-5-6:2000 IEC 60947-5-6:1999
Electromagnetic compatibility		NE 21:2007
Standards		EN 60947-5-2:2007
		EN 60947-5-2/A1:2012
		IEC 60947-5-2:2007
		IEC 60947-5-2 AMD 1:2012
Approvals and certificates		
EAC conformity		TR CU 012/2011
FM approval		
Control drawing		116-0165
UL approval		cULus Listed, General Purpose
CSA approval		cCSAus Listed, General Purpose
CCC approval		CCC approval / marking not required for products rated ≤36 V

Dimensions



1

Electrical Connection



Equipment protection level Ga		
CE marking		C€0102
ATEX marking		(x) II 1G Ex ia IIC T6T1 Ga The Ex-related marking can also be printed on the enclosed label.
Standards		EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions
Appropriate type		NCB2-12GMN0
Effective internal capacitance	Ci	\leq 90 nF ; a cable length of 10 m is considered.
Effective internal inductance	Li	\leq 100 μH ; a cable length of 10 m is considered.
Ambient temperature		Details of the correlation between the type of circuit connected, the maximum permissible ambient temperature, the temperature class, and the effective internal reactance values can be found on the EC-type examination certificate. Note: Use the temperature table for category 1 !!! The 20 % reduction in accordance with EN 1127-1 has already been applied to the temperature table for category 1.
Equipment protection level Gb		
CE marking		C€ 0102
ATEX marking		$\langle \!$
Standards		EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions
Appropriate type		NCB2-12GMN0
Effective internal capacitance	Ci	\leq 90 nF ; a cable length of 10 m is considered.
Effective internal inductance	Li	\leq 100 μH ; a cable length of 10 m is considered.
Maximum permissible ambient ter	nperature T _{amb}	Details of the correlation between the type of circuit connected, the maximum permissible ambient temperature, the temperature class, and the effective internal reactance values can be found on the EC-type examination certificate.
Equipment protection level Gc (id	;)	
Equipment protection level Gc (in Certificate	2)	PF 13 CERT 2895 X
Equipment protection level Gc (in Certificate CE marking)	PF 13 CERT 2895 X C €
Equipment protection level Gc (in Certificate CE marking ATEX marking	>)	PF 13 CERT 2895 X C (i) II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label
Equipment protection level Gc (in Certificate CE marking ATEX marking Standards	;)	PF 13 CERT 2895 X C (i) II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions
Equipment protection level Gc (in Certificate CE marking ATEX marking Standards Effective internal capacitance	;) C _i	PF 13 CERT 2895 X C ((:) II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions ≤ 90 nF ; a cable length of 10 m is considered.
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance	c _i	PF 13 CERT 2895 X C € (★) II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions ≤ 90 nF ; a cable length of 10 m is considered. ≤ 100 μH ; A cable length of 10 m is considered.
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions	C _i L _i	PF 13 CERT 2895 X C € (x) II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions < 90 nF ; a cable length of 10 m is considered. < 100 μH ; A cable length of 10 m is considered.
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6	C _i L _i	PF 13 CERT 2895 X C € Will 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions ≤ 90 nF ; a cable length of 10 m is considered. ≤ 100 μH ; A cable length of 10 m is considered. 55 °C (131 °F)
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T5	C _i L _i	PF 13 CERT 2895 X $\zeta \in$ $\langle \vdots \rangle$ II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions $\leq 90 \text{ nF}$; a cable length of 10 m is considered. $\leq 100 \mu\text{H}$; A cable length of 10 m is considered. $55 ^{\circ}\text{C} (131 ^{\circ}\text{F})$ $55 ^{\circ}\text{C} (131 ^{\circ}\text{F})$
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=34 mW, li=25 mA, T4-	c _i L _i	PF 13 CERT 2895 X $\zeta \in$ $\langle \cdot \rangle$ II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions $\leq 90 \text{ nF}$; a cable length of 10 m is considered. $\leq 100 \mu\text{H}$; A cable length of 10 m is considered. $\leq 55 ^{\circ}\text{C} (131 ^{\circ}\text{F})$ $55 ^{\circ}\text{C} (131 ^{\circ}\text{F})$ $55 ^{\circ}\text{C} (131 ^{\circ}\text{F})$
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T6	c _i L _i	$FF 13 CERT 2895 X$ $C \in$ $S II 3G Ex ic IIC T6T1 Gc$ The Ex-significant identification is on the enclosed adhesive label $EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions \leq 90 \text{ nF}; a \text{ cable length of 10 m is considered.} \leq 100 \mu\text{H}; A \text{ cable length of 10 m is considered.} 55 ^{\circ}C (131 ^{\circ}F) 55 ^{\circ}C (131 ^{\circ}F) 55 ^{\circ}C (131 ^{\circ}F) 55 ^{\circ}C (131 ^{\circ}F) 55 ^{\circ}C (131 ^{\circ}F)$
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T5	C _i L _i	$FF 13 CERT 2895 X$ $C \in$ $S = 100 \mu H ; A cable length of 10 m is considered.$ $S = 55 °C (131 °F)$ $S = C (131 °F)$
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T5 for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4-	C _i L _i T1	PF 13 CERT 2895 X C C C C C C E N B 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions \leq 90 nF ; a cable length of 10 m is considered. \leq 100 µH ; A cable length of 10 m is considered. 5 5 °C (131 °F) 5 5 °C (131 °F)
Equipment protection level Gc (in Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=69 mW, li=25 mA, T4- for Pi=169 mW, li=25 mA, T4- for Pi=169 mW, li=25 mA, T4-	с і ц т1	PF 13 CERT 2895 X C C C C C C E N B 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions \leq 90 nF ; a cable length of 10 m is considered. \leq 100 µH ; A cable length of 10 m is considered. 5 5 °C (131 °F) 5 5 °C (131 °C) 5 5 °C (131 °C) 5 5 °C (131 °C) 5 5 °C (131 °C) 1
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=69 mW, li=25 mA, T4- for Pi=169 mW, li=52 mA, T5	 Сі Ці Т1 Т1 	PF 13 CERT 2895 X C C C C C C C C
Equipment protection level Gc (id Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=69 mW, li=25 mA, T4- for Pi=169 mW, li=25 mA, T4- for Pi=169 mW, li=52 mA, T4-	 Сі Ці Т1 -Т1 	PF 13 CERT 2895 X $\zeta \in$ $\langle \bullet \rangle$ II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions \leq 90 nF ; a cable length of 10 m is considered. \leq 100 µH ; A cable length of 10 m is considered. 55 °C (131 °F) 55 °C (131 °F) 57 °C (131 °F) 5
Equipment protection level Gc (in Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=169 mW, li=52 mA, T4- for Pi=242 mW, li=76 mA, T6-	 Сі Сі Ці Т1 Т1 Т1 Т1 	PF 13 CERT 2895 X
Equipment protection level Gc (in Certificate CE marking ATEX marking Standards Effective internal capacitance Effective internal inductance Special conditions for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T6 for Pi=34 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=64 mW, li=25 mA, T4- for Pi=169 mW, li=52 mA, T4- for Pi=242 mW, li=76 mA, T5- for Pi=242 mW, li=76 mA, T5- for Pi=242 mW, li=76 mA, T5-	>) Ci Li T1 T1 -T1 i	PF 13 CERT 2895 X (ϵ (a) II 3G Ex ic IIC T6T1 Gc The Ex-significant identification is on the enclosed adhesive label EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection category "ic" Use is restricted to the following stated conditions \leq 90 nF; a cable length of 10 m is considered. \leq 100 µH; A cable length of 10 m is considered. 55 °C (131 °F) 55 °C (131 °F) 52 °C (131 °F) 54 °C (131 °F) 52 °C (131 °F) 52 °C (131 °F) 52 °C (131 °F) 53 °C (131 °F) 53 °C (131 °F) 54 °C (131 °F) 55 °C (131 °F) 52 °C (131 °F) 52 °C (131 °F) 53 °C (131 °F) 54 °C (131 °F) 55 °C (131 °F) 55 °C (131 °F) 52 °C (131 °F) 52 °C (131 °F) 53 °C (131 °F) 53 °C (131 °F) 54 °C (131 °F) 55 °C (131 °F) 57 °C (131 °F) 57 °C (131 °F) 58 °C (131 °F) 59 °C (131 °F) 50

Equipment protection level Gc (nL)	
Standard conformity	EN 60079-15:2005 Ignition protection category "n" Use is restricted to the following stated conditions
Effective internal capacitance Ci	\leq 90 nF ; a cable length of 10 m is considered.
Effective internal inductance L _i	\leq 100 μH ; A cable length of 10 m is considered.
General	The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual. The data stated in the data sheet are restricted by this operating instruction! The special conditions must be observed! The ATEX Directive applies only to the use of apparatus under atmospheric conditions. If you use the device outside atmospheric conditions, consider that the permissible safety parameters should be reduced.
Special conditions	
for Pi=34 mW, li=25 mA, T6	55 °C (131 °F)
for Pi=34 mW, li=25 mA, T5	55 °C (131 °F)
for Pi=34 mW, li=25 mA, T4-T1	55 °C (131 °F)
for Pi=64 mW, li=25 mA, T6	55 °C (131 °F)
for Pi=64 mW, li=25 mA, T5	55 °C (131 °F)
for Pi=64 mW, li=25 mA, T4-T1	55 °C (131 °F)
for Pi=169 mW, li=52 mA, T6	52 °C (125.6 °F)
for Pi=169 mW, li=52 mA, T5	52 °C (125.6 °F)
for Pi=169 mW, li=52 mA, T4-T1	52 °C (125.6 °F)
for Pi=242 mW, li=76 mA, T6	44 °C (111.2 °F)
for Pi=242 mW, li=76 mA, T5	44 °C (111.2 °F)
for Pi=242 mW, li=76 mA, T4-T1	44 °C (111.2 °F)
Equipment protection level Do	
CE marking	C€0102
ATEX marking	$\langle x \rangle$ 1D Ex is IIIC T135°C Da The Ex-related marking can also be printed on the enclosed label
Standards	EN 60079-0:2012+411:2013 EN 60079-11:2012 Ignition protection "Intrinsic safaty"
Olandaldo	Use is restricted to the following stated conditions
Appropriate type	NCB2-12GMN0
Effective internal capacitance C _i	\leq 90 nF ; a cable length of 10 m is considered.
Effective internal inductance L _i	\leq 100 μH ; a cable length of 10 m is considered.
Maximum permissible ambient temperature T_{amb}	Details of the correlation between the type of circuit connected, the maximum permissible ambient temperature, the surface temperature, and the effective internal reactance values can be found on the EC-type-examination certificate. The maximum permissible ambient temperature of the data sheet must be noted, in addition, the lower of the two values must be maintained.
Equipment protection level Dc	
	(F 0102
	The Ex-significant identification is on the enclosed adhesive label
Standards	EN 50281-1-1 Protection via housing Use is restricted to the following stated conditions
Special conditions	
Maximum heating (Temperature rise)	Values can be obtained from the following list, depending on the max. operating voltage Ub max and the minimum series resistance Rv.
at U _{Bmax} =9 V, R _V =562 Ω	9 K
using an amplifier in accordance with EN 60947- 5-6	- 9 K
Equipment protection level Dc (tc)	
CE marking	€€0102
ATEX marking	$ \label{eq: linear state of the state of$
Standards	EN 60079-0:2012+A11:2013, EN 60079-31:2014 Protection by enclosure "tc" Some of the information in this instruction manual is more specific than the information provided in the datasheet.
General	The corresponding datasheets, declarations of conformity, EC-type examination certificates, certifications, and control drawings, where applicable (see datasheets), form an integral part of this document. These documents can be found at www.pepperl-fuchs.com. The maximum surface temperature of the device was determined without a layer of dust on the apparatus. Some of the information in this instruction manual is more specific than the information provided in the datasheet.
Special conditions	
Maximum permissible ambient temperature T_{Umax}	Values can be obtained from the following list, depending on the max. operating voltage Ub max and the minimum series resistance Rv.
at U _{Bmax} =9 V, R_V =562 Ω	61 °C (141.8 °F)
using an amplifier in accordance with EN 60947- 5-6	- 61 °C (141.8 °F)

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

Germany: +49 621 776 1111 fa-info@de.pepperl-fuchs.com Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com