











Model Number

NJ8-18GM-N-10M

Features

- **Comfort series**
- 8 mm non-flush

Accessories

BF 18

Mounting flange, 18 mm

Technical Data

General specifications

Normally closed (NC) NAMUR Switching function Output type Rated operating distance 8 mm Installation non-flush Assured operating distance 0 ... 6.48 mm 0.4 Reduction factor r_{Cu} 0.3 Reduction factor r₃₀₄ 0.85 Output type 2-wire

Nominal ratings

Nominal voltage Operating voltage UB 5 ... 25 V 0 ... 200 Hz 3 % Switching frequency Hysteresis

Current consumption

Measuring plate not detected ≥ 3 mA at nominal voltage Measuring plate detected \leq 1 mA at nominal voltage

Ambient conditions

Ambient temperature -25 ... 100 °C (-13 ... 212 °F)

Mechanical specifications

Connection type cable PVC , 10 m Core cross-section 0.75 mm² Stainless steel 1.4305 / AISI 303 Housing material Sensing face

PBT Degree of protection IP67

Bending radius > 10 x cable diameter

General information

Use in the hazardous area see instruction manuals Category 1G; 2G; 1D

Compliance with standards and

directives

Standard conformity NAMUR EN 60947-5-6:2000

IEC 60947-5-6:1999 EN 60947-5-2:2007 Standards EN 60947-5-2/A1:2012 IEC 60947-5-2:2007

Approvals and certificates

EAC conformity TR CU 012/2011


FM approval Control drawing 116-0165

cULus Listed, General Purpose **UL** approval CSA approval cCSAus Listed, General Purpose


CCC approval CCC approval / marking not required for products rated ≤36 V

IEC 60947-5-2 AMD 1:2012

Dimensions



Electrical Connection



Equipment protection level Ga		
CE marking		€0102
ATEX marking		(x) II 1G Ex ia IIC T6T1 Ga The Ex-related marking can also be printed on the enclosed label.
Standards		EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions
Appropriate type		NJ 8-18GM-N
Effective internal capacitance	C _i	≤ 70 nF; a cable length of 10 m is considered.
Effective internal inductance	L _i	$\leq 50\mu H$; a cable length of 10 m is considered.
Ambient temperature		Details of the correlation between the type of circuit connected, the maximum permissible ambient temperature, the temperature class, and the effective internal reactance values can be found on the EC-type examination certificate. Note: Use the temperature table for category 1 !!! The 20 % reduction in accordance with EN 1127-1 has already been applied to the temperature table for category 1.
Equipment protection level Gb		
CE marking		C € 0102
ATEX marking		Il 1G Ex ia IIC T6T1 Ga The Ex-significant identification is on the enclosed adhesive label
Standards		EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions
Appropriate type		NJ 8-18GM-N
Effective internal capacitance	C _i	≤ 70 nF; a cable length of 10 m is considered.
Effective internal inductance	L _i	\leq 50 μH ; a cable length of 10 m is considered.
Maximum permissible ambient temperature T _{amb}		Details of the correlation between the type of circuit connected, the maximum permissible ambient temperature, the temperature class, and the effective internal reactance values can be found on the EC-type examination certificate.
Equipment protection level Da		
CE marking		C € 0102
ATEX marking		(x) II 1D Ex ia IIIC T135°C Da The Ex-related marking can also be printed on the enclosed label.
Standards		EN 60079-0:2012+A11:2013 EN 60079-11:2012 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions
Appropriate type		NJ 8-18GM-N
Effective internal capacitance	Ci	≤ 70 nF; a cable length of 10 m is considered.
Effective internal inductance	L _i	\leq 50 μH ; a cable length of 10 m is considered.
Maximum permissible ambient temperature T _{amb}		Details of the correlation between the type of circuit connected, the maximum permissible ambient temperature, the surface temperature, and the effective internal reactance values can be found on the EC-type-examination certificate. The maximum permissible ambient temperature of the data sheet must be noted, in addition, the lower of the two values must be maintained.